



Certificate of Compliance

Certificate: 70007145

Master Contract: 176847

Project: 70007145

Date Issued: December 3, 2014

Issued to: **Flowserve Corporation/EMA**
Palmstierna International AB
Korta Gatan 9
Solna, 171 54
Sweden
Attention: Mats Ragnarsson

The products listed below are eligible to bear the CSA Mark shown



Sorin Tat

Issued by: Sorin Tat

PRODUCTS

CLASS 2258 02 - PROCESS CONTROL EQUIPMENT - For Hazardous Locations

Class I, Groups B, C, and D; Class II, Groups E, F and G; Class III:

- Model F5EX Series feedback units, rated 28V dc max; 24mA max, Models F5EX-MEC, -MEC/420, □MEC/POT,

-NAM, -NAM/420, -NAM/POT, -POT, -420, -PXY, -PXY/420, -PXY/POT, enclosure Type 4X. Temperature Code T6 (amb. +50C max), T5(amb + 60C max), T4 (amb + 80C)

APPLICABLE REQUIREMENTS

CSA Std C22.2 No. 25-1966 - Enclosures for Use in Class II, Groups E, F and G Hazardous Locations

CSA Std C22.2 No. 30-M1986 - Explosion-Proof Enclosures for Use in Class I Hazardous Locations

CAN/CSA-C22.2 No. 94-M91 - Special Purpose Enclosures



Certificate: 70007145

Master Contract: 176847

Project: 70007145

Date Issued: December 3, 2014

CSA Std C22.2 No. 142-M1987 - Process Control Equipment