



Certificate of Compliance

Certificate: 1278854

Master Contract: 176847

Project: 1278854

Date Issued: February 7, 2002

Issued to: Palmstiernas Instrument AB
Korta Gatan 9
Solna, 171 54
SWEDEN
Attention: Mr. Mats Ragnarsson

The products listed below are eligible to bear the CSA Mark shown




Issued by: R. Wildish


Authorized by: Mick Alfano
Operation Manager

PRODUCTS

CLASS 2258 02 - PROCESS CONTROL EQUIPMENT - For Hazardous Locations

Class I, Div. 1, Groups C and D; Class II, Div. 1, Groups E, F and G; Class III, Div. 1; Encl. Type 4X:

Model D3E xUx23PVBZxX Electronic-Pneumatic Valve Positioner; input rated 28 Vdc, 24 mA max; Temp. Code T6 @ Max Ambient 65 Deg C; Temp. Code T5 @ Max Ambient 81 Deg C.

Note: the x's in the D3E model code denote minor mechanical and electrical variations.



Certificate: 1278854
Project: 1278854

Master Contract: 176847
Date: February 7, 2002

APPLICABLE REQUIREMENTS

CSA Std C22.2 No.	25-1966	-	Enclosures for Use in Class II, Groups E, F and G Hazardous Locations
CSA Std C22.2 No.	30-M1986	-	Explosion-Proof Enclosures for Use in Class I Hazardous Locations
CAN/CSA-C22.2 No.	94-M91	-	Special Purpose Enclosures
CSA Std C22.2 No.	142-M1987	-	Process Control Equipment

MARKINGS

- CSA Monogram;
- Company name;
- Model number;
- Serial number;
- Electrical rating
- Hazardous locations designations;
- Special purpose enclosure designation; "Encl. TYPE 4X";
- Temperature Code Rating
- Maximum Ambient Temperature
- Caution re. Seal required within 50 mm of enclosure.
- Warning re. "Keep cover tight while circuits are alive" or "Do not open while energized".



Supplement to Certificate of Compliance

Certificate: 1278854

Master Contract: 176847

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
1278854	Feb. 7, 2002	Original Certification - Model D3E Valve Positioner