



Certificate of Compliance

Certificate: 1278854

Master Contract: 176847

Project: 2208387

Date Issued: 2010/01/21

Issued to: Flowserve Sweden

**Palmstierna International AB
Korta Gatan 9
Solna, 171 54
Sweden
Attention: Mats Ragnarsson**

The products listed below are eligible to bear the CSA Mark shown



Matthew Brock

Issued by: Matthew Brock

PRODUCTS

CLASS 2258 02 - PROCESS CONTROL EQUIPMENT - For Hazardous Locations

Class I, Div. 1, Groups B, C and D; Class II, Div. 1, Groups E, F and G; Class III, Div. 1; Encl. Type 4X:

Model D3E Series and Logix Series 800 Electronic-Pneumatic Valve Positioner; input rated 28V dc, 24 mA max; Temp. Code T6 @ Max Ambient 65 Deg C; Temp. Code T5 @ Max Ambient 80 Deg C.

APPLICABLE REQUIREMENTS

CAN/CSA C22.2 No. 0-M91 - General Requirements - Canadian Electrical Code, Part II

(Reaffirmed 2006)

CSA Std C22.2 No. 25-1966 - Enclosures for Use in Class II, Groups E, F and G Hazardous Locations

(Reaffirmed 2004)

CSA Std C22.2 No. 30-M1986 - Explosion-Proof Enclosures for Use in Class I Hazardous Locations



Certificate: 1278854

Master Contract: 176847

Project: 2208387

Date Issued: 2010/01/21

(Reaffirmed 2007)

CAN/CSA-C22.2 No. 94-M91 - Special Purpose Enclosures

(Reaffirmed 2006)

CSA Std C22.2 No. 142-M1987 - Process Control Equipment

(Reaffirmed 2004)

CAN/CSA-C22.2 No.157-92 - Intrinsically Safe and Non-Incendive Equipment for Use in
Hazardous Locations

(Reaffirmed 2006)